

Cement Test Certificate

801 Berrimah Road, East Arm NT 0828 PO Box 39631, Winnellie NT 0821 T: +61 8 8984 0600 F: +61 8 8984 0610 www.adbri.com.au

ABN 22 009 593 515

Final

Newing Bl	Product Certified: Test Certificate Numl Produced At: Sample Code: Sample Date:	ber: 170114		Doubt
Nominal Blo	ena		Requirements	Result
Clinker	e Clag			>86.5 % Nil
Ground Granulated Iron Blast-Furnac	e Slag			
Mineral Addition			Max 7.5 %	<7.5 %
Calcium Sulphate Minor Additional Constituents			Max 5 %	<5 % Nil
Reportable P	roperty	Test Method	Requirements of AS3972	Result
3 Day Strength		AS2350.11	N/R	37.4 MPa
7 Day Strength		AS2350.11	Min 35.0 MPa	47.4 MPa
28 Day Strength		AS2350.11	Min 45.0 MPa	65.2 MPa
Initial Set Time		AS2350.4	Min 45 min	120 min
Final Set Time		AS2350.4	Max 360 min	195 min
Soundness		AS2350.5	Max 5 mm	1 mm
Sulfuric Anhydride content (Se	O ₃)	AS2350.2	Max 3.5 %	3.0 %
Chloride Ion		BH-TM-0507	Max 0.10 %	0.017 %
Other Properties				
SiO ₂		AS2350.2	N/R	19.9 %
Al ₂ O ₃		AS2350.2	N/R	5.5 %
Fe ₂ O ₃		AS2350.2	N/R	2.9 %
CaO		AS2350.2	N/R	63.9 %
MgO		AS2350.2	N/R	1.3 %
Na ₂ O Equivalent		AS2350.2	N/R	0.6 %
Loss on Ignition		AS2350.2	N/R	2.2 %
Fineness Index		AS2350.8	N/R	330 m²/kg
Normal Consistency		AS2350.3	N/R	30.5 %

This document shall not be reproduced except in full.

REMARKS

These test results apply specifically to the above designated sample as received for the date shown.

Adelaide Brighton Cement Birkenhead Laboratory (Accredited number: 252), 62 Elder Rd Birkenhead 5015, is responsible for testing in accordance with AS2350.2:2006, AS2350.8:2006 and in-house method BH-TM-0507.

Adelaide Brighton Cement Angaston Laboratory (Accredited number: 73), Stockwell Rd Angaston 5353, is responsible for testing in accordance with AS2350.3:2006, AS2350.4:2006, AS2350.5:2006, AS2350.11:2006 and AS2350.12:2006.

This despatch grab sample complies to the requirements of AS3972:2010, Type GP Cement.

N/R = No Requirement



Accredited for compliance with ISO/IEC 17025 - Testing. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards.

Approved Signatory F. Pope

Issue Date: 26/06/2017