

## **Cement Test Certificate**

801 Berrimah Road, East Arm NT 0828 PO Box 39631, Winnellie NT 0821 T: +61 8 8984 0600 F: +61 8 8984 0610 www.adbri.com.au

ABN	22	009	593	515	

## Final

Type GP General Purpose Cement

**Product Certified:** 

	<i>·</i> · ·			
Test Certificate	<b>Number:</b> 170554	170554		
Produced At:	Northern C	Northern Cement, Darwin Plant, NT		
Sample Code:	B05de46			
Sample Date:	13/09/201	13/09/2017		
Nominal Blend		Requirements	Result	
Clinker			>86.5 %	
Ground Granulated Iron Blast-Furnace Slag			Nil	
Mineral Addition		Max 7.5 %	<7.5 %	
Calcium Sulphate			<5 %	
Minor Additional Constituents		Max 5 %	Nil	
		Requirements of	_	
Reportable Property	Test Method	AS3972	Result	
3 Day Strength	AS2350.11	N/R	39.3 MPa	
7 Day Strength	AS2350.11	Min 35.0 MPa	50.8 MPa	
28 Day Strength	AS2350.11	Min 45.0 MPa	64.0 MPa	
Initial Set Time	AS2350.4	Min 45 min	90 min	
Final Set Time	AS2350.4	Max 360 min	210 min	
Soundness	AS2350.5	Max 5 mm	1 mm	
Sulfuric Anhydride content (SO <sub>3</sub> )	AS2350.2	Max 3.5 %	2.9 %	
Chloride Ion	ASTM C114	Max 0.10 %	0.006 %	
Other Properties				
SiO <sub>2</sub>	AS2350.2	N/R	20.0 %	
Al <sub>2</sub> O <sub>3</sub>	A\$2350.2	N/R	5.3 %	
Fe <sub>2</sub> O <sub>3</sub>	A\$2350.2	N/R	2.8 %	
CaO	A\$2350.2	N/R	64.4 %	
MgO	A\$2350.2	N/R	1.4 %	
Na <sub>2</sub> O Equivalent	AS2350.2	N/R	0.6 %	
Loss on Ignition	A\$2350.2	N/R	2.0 %	
Fineness Index	AS2350.8	N/R	355 m²/kĮ	
Normal Consistency	AS2350.3	N/R	28.2 %	

This document shall not be reproduced except in full.

## REMARKS

These test results apply specifically to the above designated sample as received for the date shown.

Adelaide Brighton Cement Birkenhead Laboratory (Accredited number: 252), 62 Elder Rd Birkenhead 5015, is responsible for testing in accordance with AS2350.2:2006, AS2350.8:2006 and in-house method BH-TM-0507.

Adelaide Brighton Cement Angaston Laboratory (Accredited number: 73), Stockwell Rd Angaston 5353, is responsible for testing in accordance with AS2350.3:2006, AS2350.4:2006, AS2350.5:2006, AS2350.11:2006 and AS2350.12:2006.

This despatch grab sample complies to the requirements of AS3972:2010, Type GP Cement.

N/R = No Requirement



Accredited for compliance with ISO/IEC 17025 - Testing. The results of the tests, calibrations and/or measurements included in this document are traceable to Australian/national standards.

24/10/2017

**Approved Signatory** F. Pope

Issue Date: